

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-6330AT2061Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Hans Sasserath & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Distributor <i>Vertreiber</i>	Hans Sasserath & Co. KG Mühlenstraße 62, D-41352 Korschenbroich
Product Category <i>Produktart</i>	valves for drinking water : cold water pressure reducing valve (6330)
Product Description <i>Produktbezeichnung</i>	cold water pressure reducing valve
Model <i>Modell</i>	314.1; 4315; 315; 315 AB; 315.1; 315.2
Test Reports <i>Prüfberichte</i>	mechanical test: KT 098/12 from 05.07.2013 (TZW) type testing: DM 006/10+007/10+008/10 from 03.02.2011 (TZW) type testing: DM 009/10+010/10+011/10 from 03.02.2011 (TZW) KTW testing: KA 0024/13 from 31.01.2013 (TZW) hygienic testing: W-170254-08-SI from 19.11.2008 (WHY) KTW testing: 09308_02 from 08.08.2008 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 1567 (01.01.2000) BGA KTW (12.12.1985) UBA KTW (07.10.2008) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	21.12.2018 / 13-0041-WNV

70028-01-A-DE

17.09.2013 Wg A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

DVGW CERT GmbH is an accredited body by DAkkS according to EN 45011:1998 for certification of products for energy and water supply industry.

DVGW CERT GmbH ist von der DAkkS nach DIN EN 45011:1998 akkreditierte Stelle für die Zertifizierung von Produkten der Energie- und Wasserversorgung.

Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01DVGW CERT GmbH
ZertifizierungsstelleJosef-Wirmer-Str. 1-3
53123 BonnTel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993www.dvgw-cert.com
info@dvgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
314.1; 4315; 315; 315 AB; 315.1; 315.2	pressure rating: PN 16 nominal diameter: DN 15	
4315; 315; 315 AB; 315.1; 315.2	pressure rating: PN 16 nominal diameter: DN 20	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 25	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 32	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 40	
4315; 315; 315 AB; 315.2	pressure rating: PN 16 nominal diameter: DN 50	

Type Variation Ausführungsvariante	Explanations Erläuterungen
314.1; 315.1	inlet side: external thread, outlet side: connection adapter only in combination with a drinking water safety unit
315; 315 AB; 4315; 315.2	inlet and outlet side: threaded connection with external thread

Hints of Utilization / Remarks Verwendungshinweise / Bemerkungen
ABP for types 315 and 315 AB: P-IX 7635/I (noise class I: DN 15, DN 20, DN 25)